



Installation Smartline Terminal Power Strip : 935-T6DS

Kondator
www.kondator.se


1



OR



2



Ext. cable not included




Ext. cable not included

POWER (WIELAND)

WIELAND GST18I3S Female type
Part no 92.931.3053.1
VDE Approval no. 40018414

Cable cord specification
H05VV-F according to EN 50525-2-11
minimum 3 x 1.5 mm²



Accessories
Wieland <-> Schuko
1.5 m 935-BA15
3.0 m 935-BA30
5.0 m 935-BA50

Recommended Accessories

935-TA50 TopAccess Conference Outlet Box



935-C093 Allround Cable Tray

